

Number of heaters *	The maximum flow [m <sup>3</sup> ]	The diameter of the pipeline [“]
1	1,5	$\frac{3}{4}$
2	3	1
3	4,5	1 $\frac{1}{4}$
4	6	1 $\frac{1}{2}$
5	7,5	1 $\frac{1}{2}$
6	9	2
7	10,5	2
8	12	2
9	13,5	2 $\frac{1}{2}$
10	15	2 $\frac{1}{2}$

\*Air water heaters Reventon Group are connected to the main pipe in sequence.

**OUR HEAD OFFICE:**

Reventon Group Sp. z o.o. [Ltd.] export@reventongroup.eu  
 3B Montażowa n.korszun@reventongroup.eu  
 43-300 Bielsko-Biała +48 791 40 40 40  
 POLAND +48 793 40 40 40  
 +48 33 482 77 36

VAT ID PL 937-267-50-06

www.reventongroup.eu

